

ADDENDUM NO. 3

Citywide Street Reconstruction Phase 5 City Project No. 467773-05

Addendum No. 3 is issued to the above-referenced project, which is scheduled for bid opening on February 5, 2026 at 2:00 p.m.

The following changes have been made.

BID DATE:

- No change.

CONTRACT BOOK:

- No change.

RESPONSES TO ADDITIONAL BIDDER QUESTIONS:

1. **Q: Are we allowed to directional bore the conduits?**

A: No.

2. **Q: Can HDPE conduits be used in lieu of PVC?**

A: No.

3. **Q: On the electrical drawings, demo part, it shows to remove conduits and conductors. Please clarify if we can remove only the conductors and abandon the existing conduits in place?**

A: Both conductors and conduits must be removed from the ground.

ADDENDUM NO. 3

**Citywide Street Reconstruction Phase 5
City Project No. 47773-05**

ACKNOWLEDGEMENT

I have received Addendum No. 3 to the Contract Book titled, "Citywide Street Reconstruction Phase 5", City Project No. 47773-05. I have read and understand the information stated in the addendum.

Date

Bidder's Signature

Bidder's Name (Printed)

Name of Company

RETURN WITH BID DOCUMENTS